


Customer: ELFA AB

56-122-70

Transf. No. AA-58028
Designed: 1995-03-23 / ts



Classification

Protection against electrical shock:	Isolating Transformer
Protection index:	IP00
Protection against short-circuit and abnormal use:	Non-short-circuit proof
Time of operation:	Continously
Intended use:	Incorporated
Ambient temperature / Material Classification:	Ta40/E

Assembling: 1 pc Metal Washer D = 60 mm

2 pcs Rubber Pads D = 60 mm

Dimensions: OD = 78 mm

Prim:

H = 35 mm

Multistranded Wire Style 3266.

Sec: Solid Copper insulated with tubes of Natvar. L = 200mm

Awg 22

L = 200mm


Label on the paper box.

Terminations:

Toroid International AB
Transf.No. AA-58028

ELFA P/N: 56-122-70

Label on transformer.





Declaration of Insulation Transformer No. AA-58028
Customer: ELFA AB
Customer Part No: 56-122-70

This transformer is CSA- and UL-Recognized, File No. E115159, according to following standards:

UL1950 & CAN/CSA C22.2 No. 950-95

Standard for safety for Information Technology Equipment, including Electrical Business Equipment.

The construction of this transformer also fulfill the requirements according to IEC 601.1, EN 61558-1, EN 60 950, EN 60 065, UL 2601.1, UL 6500, UL 1411.

Core.

The core is tapewound with cold-rolled grainoriented silicon steel.

Core Dimensions: 70x40x20 mm

Core Protection.

The core is insulated with min. four layers of 0,05mm thick Polyesterfilm.

UL-Approved under Guide QMFZ2. Flame Class UL 94VTM-2. Approved for 130°C.

Copper Wire.

Polyesterimid enamelled copper wire, according to IEC 317-13.

Approved for min. 180°C.

Primary Termination.

Stranded wire: Awg 22

UL-Approved under Guide AVLV2, Style 3266. Approved for 300V and 125°C.

Plus an extra insulation tube. UL-Approved under Guide YDPU2. Approved for 105°C.

Secondary Termination.

The wire ends are insulated with insulation tubes.

UL-Approved under Guide YDPU2. Approved for 300V and 105°C.

Insulation Primary - Secondary.

The insulation between the primary and the secondary consists of min. four layers of 0,05mm thick Polyester film (total thickness min. 0,2mm).

UL-Approved under Guide QMFZ2. Flame Class UL 94VTM-2. Approved for 130°C.

Two of these layers withstands together 4000Vac for one minute. The creep distance exceeds 8mm and the insulation resistance is more than 5000 Megohm.

Final Insulation.

The outer insulation consists of min. two layers of 0,05mm thick Polyester film. UL-Approved under Guide QMFZ2. Flame Class UL 94VTM-2. Approved for 130°C.

Mounting Hardware.

Washer mounting, consisting of one metal washer and two rubber pads.



EC/EEA Declaration of conformity

Type of equipment: Isolating Transformer

Brand name: Toroid

Part no: **AA-58028**

Customer: ELFA AB 56-122-70

Manufactures: Toroid International (Pvt) Ltd Toroid International AB

PO Box 15, Phase 2, FTZ Box 3

Katunayake, Sri-Lanka 351 03 Växjö, Sweden

Toroid India Pvt Ltd Manufacture's representative

Technopark Campus within EEA: Toroid International AB

Trivandrum 695 581 Box 3

Kerala, India 351 03 Växjö, Sweden

As the manufacturer's authorised representative established within EEA, we declare that the product is in conformity with the provision of the EC directives: Low Voltage Directiven (LVD) 73/23/EEG, 93/68/EEG

The product fulfils the requirements according to the following harmonised standards: EN 61558-1, EN 60 950, EN 60 065 and IEC 601-1.

All transformers have been inspected and tested with approved result according to the following:

- 1. Ocular inspection
- 2. No-load input current
- 3. No-load secondary voltage
- 4. Dielectric strength between primary an

The product is to be regarded as a modular component to be used in an electric apparatus that in turn has to fulfil the EMC - directives.

The product itself does not need to be EMC approved for CE marking according to directive 89/336/EEG, 92/31/EEG and 93/68/EEG

Date: 2003-05-07

Thomas Svensson / Design engineer