DATASHEET - MCS4-SOND910-G



Pressure switch, 2W gold-plated, 7bar

Part no. MCS4-SOND910-G Catalog No. 087792


Eaton Catalog No. MCS4-SOND910-G



Delivery program

| Note on use | | This product complies with Low-Voltage Directive 2014/35/EC and EMC Directive 2014/30/EC and meets the requirements in EN 60947-5-1. This product does not meet the rail industry's standard requirements. Accordingly, the user must review it separately for the specific application at hand. |
|---|-----|--|
| Product range | | Pressure switches with auxiliary contacts |
| Degree of Protection | | IP65 |
| Contacts | | 2 changeover contact with gold-plated contacts |
| Cut-in pressure and cut-out pressure: separate stepless adjustment. All the intersection points within the diagram area can be set. | | |
| | | 1 2 4 4 5 0 1 1 2 3 4 4.5 0 0 1 1 2 3 4 4.5 Cut-out pressure |
| | | Min. switching differential: 0.15 bar Example: |
| | | Cut-out pressure 3.3 bar |
| | | Cut-in pressure 2.2 bar |
| | | Variable switching differential |
| Max. operating pressure | bar | 7 |

Notes



Features:

- Pressure pipe flange R ¼"
- If required: pressure pipe flange R ½"
- IP65 in conjunction with V-M20 cable gland
- 2 cable entry knockouts for M20
- Neoprene membrane, resistant to aging, air, engine oil, and water min. -25 °C, max. +80 °C

Cut-in and cut-out pressures are factory-preset as specified with part no. suffix: →#203948

R ¼" corresponds to G ¼

R ½" corresponds to G ½ according to ISO 228-1

Auxiliary contact in accordance with IEC/EN 60947-5-1

Notes

Gold-plated contacts, particularly suitable for switching low voltages and currents from 5 V AC/DC 1 mA.

Technical data

General

| donoral | | |
|--------------------|-----|------------------|
| Standards | | IEC/EN 60947-5-1 |
| Test pressure | bar | 32 |
| Rupturing pressure | bar | 90 |

| Operating frequency | Operations/h | | ≦ 1500 |
|---|------------------------------------|-------------------|--|
| Climatic proofing | | | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature | | | -25 - 70 |
| Degree of Protection | | | IP65 |
| Mounting position | | | As required |
| Mechanical shock resistance to IEC 60068-2-27 | Half- sinusoidal shock 20 ms | g | > 10 |
| Vibration resistance acc. to IEC/EN 60068-2-6 | Amplitude 1 mm | Hz | 36 |
| lifespan | Operations | x 10 ⁶ | 1 |
| Terminal capacities | | mm ² | |
| Solid | | mm ² | 1 x (0.75 - 2.5) 2 x (0.75 - 1.5) |
| Flexible with ferrules to DIN 46228 | | mm^2 | 1 x (0.5 - 1.5) |
| Terminations | | | Tunnel terminal |
| Terminal screw | | | M2.6 |
| Tightening torque of terminal screw | | Nm | 0.4 |
| Contacts/switching capacity | | | |
| Rated impulse withstand voltage | U_{imp} | V AC | 1500 |
| Rated insulation voltage | Ui | V | 125 |
| Overvoltage category/pollution degree | | | III/3 |
| Max. short-circuit protective device | | | |
| Fuse | gG/gL | Α | 2 |
| AC-15 | | | |
| Rated operational current | | | |
| 230 V, 50/60Hz | | Α | 2 |
| DC-13 | | | |
| Rated operational current | | | |
| 24 V | | Α | 1 |
| 110 V | | Α | 0.25 |
| | | | |

Design verification as per IEC/EN 61439

| Technical data for design verification | | |
|--|----|-----|
| Operating ambient temperature min. | °C | -25 |
| Operating ambient temperature max. | °C | 70 |

50

Technical data ETIM 7.0

Rated frequency

| Low-voltage industrial components (EG000017) / Pressure switch (EC000243) |
|---|
| Floatic analyzaring automatical process control analyzaring / Low voltage switch technology / Manitoring aguinment flow voltage switch technology / Process aguinment |

Electric engineering, automation, process control engineering / Low-voltage switch technology / Monitoring equipment (low-voltage switch technology) / Pressure monitoring equipment (ecl@ss10.0.1-27-37-18-14 [AKF108014])


| ecl@ss10.0.1-27-37-18-14 [AKF108014]) | | | |
|---------------------------------------|----|----|-------------------------------------|
| Suitable as guard | | | Yes |
| Suitable as 2-point controller | | | Yes |
| Suitable as limiter | | | No |
| Max. operation pressure | hF | Pa | 7000 |
| Engaging pressure | ba | ar | 0 - 4.2 |
| nitial setting | hF | Pa | 0 - 0 |
| Switch off pressure | ba | ar | 0 - 4.5 |
| End setting | hF | Pa | 0 - 0 |
| Pressure-switching differential | ba | ar | 0 |
| Max. test pressure | ba | ar | 32 |
| Bursting pressure | ba | ar | 90 |
| Medium temperature | °C | 3 | 25 - 80 |
| Connection | | | Inner thread gas cylindrical (BSPP) |
| Thread size | | | 1/2 inch |


| Rated voltage Ue at AC 50 Hz | ٧ | 0 - 0 |
|---|----|------------------|
| Rated voltage Ue at AC 60 Hz | ٧ | 0 - 0 |
| Rated voltage Ue at DC | ٧ | 0 - 110 |
| Initial value measuring range pressure | Pa | 0 |
| End value measuring range pressure | Pa | 0 |
| Rated operation power at AC-3, 400 V | kW | 0 |
| Switching capacity at AC-3, 240 V | kA | 0 |
| Rated operation current le at AC-1, 400 V | Α | 0 |
| Rated operation current le at AC-3, 400 V | Α | 0 |
| Number of auxiliary contacts as normally open contact | | 0 |
| Number of auxiliary contacts as normally closed contact | | 0 |
| Number of auxiliary contacts as change-over contact | | 2 |
| Type of electric connection | | Screw connection |
| Number of normally closed contacts as main contact | | 0 |
| Number of main contacts as normally open contact | | 0 |
| Adjustable current range | Α | 0 - 0 |
| With hand operation | | No |
| With manual on/off switch | | No |
| Electronic version | | No |
| With display | | No |
| Explosion-proof | | No |
| Degree of protection (IP) | | IP65 |
| Degree of protection (NEMA) | | Other |
| Height | mm | 110 |
| Width | mm | 60 |
| Diameter | mm | 0 |
| Depth | mm | 96 |

Approvals

| Product Standards | CSA-CC22.2 No. 14 |
|-----------------------------|-------------------|
| CSA File No. | 12528 |
| CSA Class No. | 3211-06 |
| North America Certification | CSA certified |

Dimensions





Additional product information (links)

IL05212001Z (AWA1320-0132) Pressure switch

IL05212001Z (AWA1320-0132) Pressure switch ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL05212001Z2018_05.pdf